

TEST REPORT

No. : GZIN2407002635PL01_EN

Date : 2024-07-30

Page: 1 of 5

CUSTOMER NAME: SHENZHEN ANIKA IMPORT & EXPORT CO., LTD.
ADDRESS: 4E270, 4TH FLOOR, 210, TAIRAN TECHNOLOGY PARK, TAIRAN 4TH ROAD,
TIANAN COMMUNITY, SHATOU STREET, FUTIAN DISTRICT,
SHENZHEN, CHINA

Sample Name : sound barrier
Product Specification : 1*2M
Manufacturer : Shenzhen Anika Import & Export co., Ltd.
Material : polyester with MLV and glassfiber fabric

Above information and sample(s) was/were submitted and confirmed by the client. SGS, however, assumes no responsibility to verify the accuracy, adequacy and completeness of the sample information provided by client.

Date of Receipt : 2024-07-19
Testing Period : 2024-07-19 ~ 2024-07-30
Test result(s) : For further details, please refer to the following page(s)
(Unless otherwise stated the results shown in this test report refer only to the sample(s) tested)

Signed for
SGS-CSTC Standards Technical
Services Co., Ltd. Guangzhou
Branch.



Quincey Lee
Authorized signatory



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <https://www.sgs.com/en/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing / inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

SGS-CSTC Standards Technical Services Co., Ltd.
Guangzhou Branch

No.198, Kezhu Road, Science City, Economic & Technological Development Area, Guangzhou, Guangdong, China 510663
中国·广东·广州高新技术产业开发区科学城科珠路198号 邮编: 510663

t (86-20) 82155661 www.sgsgroup.com.cn
t (86-20) 82155661 sgs.china@sgs.com

TEST REPORT

No. : GZIN2407002635PL01_EN

Date : 2024-07-30


Page: 2 of 5

Summary of Results:

No.	Test Item	Test Method	Result	Conclusion
1	Sound Absorption Coefficient	ASTM C423-23	See Result	N/A

Note: Pass : Meet the requirements;
 Fail : Does not meet the requirements;
 N/A : Not Apply to the judgment.

Original Sample Photo:



TEST REPORT

No. : GZIN2407002635PL01_EN

Date : 2024-07-30

Page: 3 of 5

Test Item: Sound Absorption Coefficient

I. Test Method

ASTM C423-23 Standard Test Method for Sound Absorption and Sound Absorption Coefficients by the Reverberation Room Method

II. Sample Details

Dimensions	2000mm×1000mm×25mm
Surface Density	About 6.98kg/m ²

III. Test Condition

Ambient Temperature	29.3℃	Ambient Humidity	82.2%RH
Volume Reverberation Room	260m ³	Test Area	11.46m ² (3.95m×2.90m)
Description of Test Arrangement	The installation of samples refers to type A mounting. After splicing, the sample is placed directly in the reverberation room, with the back facing the noise.		

IV. Test Result

Average Absorption Coefficient $\bar{\alpha}$ (100Hz~5000Hz): 0.50

Average Absorption Coefficient SAA (200Hz~2500Hz):0.62

Noise Reduction Coefficient: NRC=0.65

Note: NRC is the arithmetic average of absorption coefficient contained four octave frequency bands (250, 500, 1000, 2000 Hz).



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <https://www.sgs.com/en/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

SGS-CSTC Standards Technical Services Co., Ltd.
Guangzhou Branch

No.198, Kazhu Road, Science City, Economic & Technological Development Area, Guangzhou, Guangdong, China 510663
中国·广东·广州高新技术产业开发区科学城科珠路198号 邮编: 510663

t (86-20) 82155661 www.sgsgroup.com.cn
t (86-20) 82155661 sgs.china@sgs.com


TEST REPORT

No. : GZIN2407002635PL01_EN

Date : 2024-07-30

Page: 4 of 5

Frequency f/Hz	Absorption Coefficient, α
100	0.06
125	0.10
160	0.12
200	0.18
250	0.30
315	0.41
400	0.64
500	0.72
630	0.75
800	0.81
1000	0.85
1250	0.86
1600	0.76
2000	0.65
2500	0.55
3150	0.47
4000	0.39
5000	0.35
$\bar{\alpha}$	0.50
SAA	0.62
NRC	0.65



Note: This declaration of conformity is only based on the result of this laboratory activity, the impact of the uncertainty of the results was not included.



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <https://www.sgs.com/en/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.
Attention: To check the authenticity of testing / inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com
No.198, Kazhu Road, Science City, Economic & Technological Development Area, Guangzhou, Guangdong, China 510663
中国·广东·广州高新技术产业开发区科学城科珠路198号 邮编: 510663
t (86-20) 82155661 www.sgs.com.cn
t (86-20) 82155661 sgs.china@sgs.com



TEST REPORT

No. : GZIN2407002635PL01_EN

Date : 2024-07-30

Page: 5 of 5

Appendix information:

*The above test was carried out by other laboratory in SGS group.

In the territory of the People's Republic of China, the test report with CMA logo expresses that the test items are within the scope of China Metrology Accreditation(CMA); without CMA logo expresses that part/all of the test items are not within the scope of China Metrology Accreditation(CMA), and just for client internal reference.

*****End of report*****



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <https://www.sgs.com/en/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

No.198, Kazhu Road, Science City, Economic & Technological Development Area, Guangzhou, Guangdong, China 510663
中国·广东·广州高新技术产业开发区科学城科珠路198号 邮编: 510663

t (86-20) 82155661 www.sgsgroup.com.cn
t (86-20) 82155661 sgs.china@sgs.com

Member of the SGS Group (SGS SA)